

CONTENTS

SECTION	Page
Contents	i
Certification	ii
PART I - GENERAL INFORMATION	1
A. GENERAL	1
1. Name and Type	1
2. Date of Initial Operation	1
3. Location	1
4. Name and Address of Owner	1
5. Facility Contacts	1
B. SITE DESCRIPTION AND OPERATIONS	2
1. Site Description	2
2. Fuel Ullage	2
3. Secondary Containment.....	2
4. Spill Risk	2
5. Location of Chemicals	2
6. Permits Required	2
PART II - OPERATIONAL PROCEDURES FOR SPILL PREVENTION.....	3
A. TANK REFUELING OPERATIONS	3
PART III - SPILL COUNTERMEASURES AND REPORTING	
A. SPILL AND COUNTERMEASURES	4
B. SPILL REPORTING	5
C. TRAINING	6
D. PERSONAL PROTECTIVE EQUIPMENT (PPE)	6

APPENDIX

- A. TANK ULLAGE/FUELING LOG AND FUEL UNLOADING PROCEDURE CHECKLIST
- B. TANK INSPECTION CHECKLIST
- C. SPILL REPORTING FORM
- D. TRAINING OUTLINE AND RECORD FORM
- E. DIESEL FUEL “MATERIALS SAFETY DATA SHEET”
- F. SPILL CLEANUP KIT INFORMATION
- G. FUEL TANK DATA AND INFORMATION SHEET
- H. PERMITS
- I. PHOTOGRAPHS OF FACILITY, TANK AND PIPING
- J. FIGURE 1, FIGURE 2 and FIGURE 3 (MAPS & DRAWINGS)

**SPILL PREVENTION, CONTROL, AND COUNTERMEASURES
BEST MANAGEMENT PLAN**

N O A A

**NATIONAL WEATHER SERVICE
Los Angeles Area Radar Facility
Sulphur Mountain
California**

Designated Person Responsible for Spill Prevention (DRO):

Printed Name: Dan Keeton - MIC

Signature: _____

Date: _____

Telephone: (805) 988-6615

The Regional Environmental Compliance Officer (RECO) has reviewed the facility and determined that an SPCC Plan is not required per 40 CFR 112. This Plan is developed strictly as a Best Management Plan. The determination is based on :

The facility does not exceed capacity.

The facility meets capacity requirements but, a discharge will not reach navigable waterways.

RECO Printed Name: Thanh Minh Trinh, P. E.
Phone: (206) 526-6647

RECO Signature: _____

Date: _____

I - GENERAL INFORMATION

A. GENERAL

This section of the Best Management Practices plan provides general information about the facility.

Name

1. National Weather Service Radar Data Acquisition Facility, Sulphur Mountain, California

2. **Date of Initial Operation**

1994 — Interior Fuel Tanks Installed In Generator Shelter

3. **Location**

National Weather Service RDA Site
Street: 9150 Sulphur Mountain Road
City: Ojai
State/Zip Code: California
Latitude: 34° -24'-42" North
Longitude: 119° -10'-46" West
Elevation: 2726 Ft. MSL
Phone: 775-673-8100

4. **Name and Address of Operator**

National Weather Service Forecast Office
520 North Elevar Street
Oxnard, California 93030
Phone: 805-988-6615

5. **Facility Contacts**

<u>Name</u>	<u>Title</u>	<u>Telephone Number</u>
Russ Bacon	Envir. Coord.	(805) 988-6615
Dan Keeton	MIC	(805) 988-6615

B. SITE DESCRIPTION AND OPERATIONS

This section describes the site and its operations.

1. The facility is located at 9150 Sulphur Mountain Road in Ventura County, California. The site is located on Sulphur Mountain approximately 5-nmi east of Ojai, California and 12.5 nmi north of the National Weather Service Forecast Office in Oxnard, California (APPENDIX J, FIGURE 1). The land is owned by Mr. William Kee and leased to the NWS. All improvements on the site are owned by the NWS. Access to the site is by wheeled vehicle on paved roads. Radar data from this site are transmitted back to the WFO via microwave link. The site consists of a plot of ground approximately 120' x 140' which contains the NWS Radar Data Acquisition (RDA) facility which includes a 20-meter high radar antenna tower with a radome and antenna, an Equipment Shelter, a Generator Shelter and an Uninterrupted Power shelter.
2. Records of past fuel ullage indicate that this site will use approximately 400-gallons of #1 Diesel Fuel each year. The fuel tanks are normally filled once and sometime twice each year depending upon the amount used. The generator is run once each week for an hour for maintenance and testing purposes. Fuel consumption depends on the frequency and duration of periods when the generator is operated.
3. Two 240 gallon, interconnected, steel day tanks are installed in the Generator Shelter to supply diesel fuel to an emergency generator. The Generator Shelter has sufficient spill containment capability to provide secondary containment sufficient to handle all of the oil in the day tanks.
4. The generator and associated fuel tanks are located on a mountain top site with the general drainage slope of the land towards the south. The soil is porous and rocky. Any spilled fuel oil from the site or the tank truck will be absorbed by the soil near the site (APPENDIX J - FIGURE 2). In the event of a fuel spill, waterways or water supply should not be impacted.
5. In addition to the diesel fuel used for the emergency power generator, this facility also stores chemicals (e.g., oils, paint, solvents, antifreeze, cleaning compounds and pesticides) for the operation, maintenance and testing of site facilities and equipment. These are stored/used in the following location(s):

Location : (Example: Flammable locker in the UPS Shelter)

- a. Unused oil in original containers — Generator Shelter
- b. Paint in spray cans — Stored in Flammables Locker located in the UPS Shelter
- c. Station Cleaning Supplies — Stored in the UPS
- d. Lubricants in spray cans — Stored in Flammables Locker located in UPS Shelter
- e. Pesticides — Stored in the UPS Shelter
- f. New Batteries — Stored in the UPS Shelter in the original containers
- g. New Fluorescent Light tubes — Stored in original containers in the UPS Shelter

6. Permits Required

None Required

Part II - OPERATIONAL PROCEDURES FOR SPILL PREVENTION

A. Tank Refueling Operations. This section discusses the procedures that shall be used during unloading of fuel from the tank truck into the AST to prevent spills. This procedure shall be documented every time refueling occurs using the form found in Appendix A. Copies of this form shall be kept for 5 years.

1. The following procedure shall be used **before** fuel unloading: (APPENDIX A)
 - a. The Facility Manager or his designated representative should determine the available capacity (ullage) of the AST by converting the reading on the fuel gauge to gallons (See Appendix A). This ullage is communicated to the fuel supply contractor and marked in the fueling log.
 - b. Move spill containment equipment such as booms, spill barriers or spill kits into the unloading area.
 - c. Block the tank truck wheels.
 - d. Place drip pans under all pump hose fittings (if applicable) before unloading.
 - e. The Facility Manager or his designated representative and the delivery driver ensure the fill nozzle is placed in the appropriate AST appurtenance.
2. The following procedure shall be used **during** the fuel unloading period: (APPENDIX A)
 - a.. The Facility Manager or his designated representative and the delivery driver shall remain with or near the vehicle and the fuel tanks at all times during unloading. Gauges on the AST and the truck, as well as the fueling nozzle, shall be continuously monitored to ensure the ullage is not exceeded. If the audible high-level alarm sounds, stop the unloading of fuel as soon as possible.
3. The following procedure shall be used **after** fuel unloading is completed: (APPENDIX A)
 - a. Record the amount of fuel transferred to the AST in the log.
 - b. Drain the fill hose and then ensure that all drain valves are closed (if applicable) before removal of the hose from the tank.
 - c. Pour any uncontaminated fuel in the drip pans, tank truck containment pool, or spill pipe spill bucket container into the AST (if it has the capacity) or dispose of appropriately.
 - d. Inspect the tank truck before removing the blocks to ensure the lines have been disconnected from the tank.
 - e. Remove the blocks from truck wheels.
 - f. Place a copy of the fuel-unloading checklist in the SPCC BMP.

PART III - SPILL COUNTERMEASURES AND REPORTING

A. SPILL COUNTERMEASURES

This section presents countermeasures to contain, clean up, and mitigate the effects of any oil spills at this site.

A spill containment and cleanup activity will never take precedence over the safety of personnel. No countermeasures will be undertaken until conditions are safe for workers. The **SWIMS** procedure should be implemented as countermeasures:

- S-** Stop the leak and eliminate ignition sources.
 - a. Attempt to seal or some how stop leak if it can be done safely.
 - b. Attempt to divert flow away from any drainage ditch, storm sewer or sanitary sewer with a spill barrier or the contents of spill kit. The spill kit is located in the Generator Building.
 - c. Eliminate all ignition sources in the immediate area.

- W-** Warn others.
 - a. Yell out "SPILL". Inform the person in-charge at your facility.
 - b. Account for all personnel and ensure their safety.
 - c. Notify contacts and emergency response contractor as described in the following section for assistance in control and cleanup.

- I-** Isolate the area.
 - a. Rope off the area

- M-** Minimize your exposure to the spilled material by use of appropriate clothing and protective equipment. If possible, remain upwind of the spilled material.

- S-** Standby to assist the emergency response contractor.

B. SPILL REPORTING (APPENDIX C):

1. General Notification Procedures For All Spills:

Within 24 hours, the responsible person or designee (on this plan title page or in Part 1, A.5.) is directly charged with reporting **all** oil spills that result from facility operations as follows:

- a. In the event of an emergency (e.g, fire, or injury), call **911**.
- b. Notify the appropriate persons within your WFO, Regional Office and line office:

National Weather Service:

Mike Jacob, NWS Environmental Compliance Officer (NWSH)

Phone number: (301) 713-1838 Ext. 165, Jmichael.Jacob@NOAA.GOV

Olga Kebis, NWS Safety Officer (NWSH)

Phone number: (301) 713-1838 Ext. 173, Olga.Kebis@NOAA.GOV

Robert Kinsinger, Regional, Environmental Coordinator (ECC) in Western Region Headquarters

Phone number: (801) 524-5138 Ext. 223 Email: robert.kinsinger@noaa.gov

- c. **NOAA Environmental Compliance and Safety Office Program:** E-mail or call your **RECO**.

WASC **Thanh.M.Trinh@NOAA.GOV** Phone: (206) 526-6647

- d. **LECO – Ventura County Hazmat** Phone: (805) 654-2813

Note: **LECO & RECO** must determine if Federal or State notification is required and follow up accordingly. (The State of Nevada requires notification when a release of petroleum products exceeds 25-gallons or if there is a potential contamination of 3 cubic yards of soil.

Call 911 and then contact the Governor’s Office of Emergency Services Warning Center at (800)852-7550

2. Cleanup Contractor Notification

An emergency response contractor should also be notified to assist with the clean up if necessary. **NWS/WFO Reno** has identified and contacted the following contractors that are available for an emergency response:

<u>Contractor(s)</u>	<u>Phone Number</u>
• PW Environmental	(805) 656-4677
• Remediation Service International	(800) 368-8685

3. Spill Report

Complete a spill report using the format provided in Appendix C. Send this to Your RECO with a copy to the Western Region ECC.

C. Training

The Environmental/Safety Focal Point and an alternate should be trained in 1) the refueling procedure, 2) countermeasures, and 3) spill reporting. The alternate should be designated in case the primary person is off site at the time of a spill. (See APPENDIX D for Training Outline and Training Record form)

D. Personal Protective Equipment (PPE)

- PPE information is specified in the **MSDS**
- Eye protection is accomplished by the use of **Chemical Goggles**
- Hand protection is accomplished by the use of **Nitril Gloves**
- Other clothing & equipment - if contaminated, must be removed and laundered before reuse. Items which cannot be laundered should be discarded.
- Appropriate NIOSH - approved respiratory protection to avoid inhalation of mist or vapors which may be present under hot temperature conditions.

APPENDIX A

**TANK ULLAGE/FUELING LOG AND FUEL UNLOADING
PROCEDURES CHECKLIST**

APPENDIX A-2

FUEL UNLOADING PROCEDURE CHECKLIST

Date: _____ **Tank:** _____

NWS Representative: _____ **Supplier:** _____

✓	ITEM	DESCRIPTION	COMMENTS
The following six items must be completed before fuel unloading:			
	1	Determine the available capacity (ullage) of the aboveground storage tank (AST) by converting the reading on the fuel gauge to gallons (See Appendix A, Page A-1). This ullage should then be marked in the fueling log and communicated to the tank truck unloading contractor.	
	2	Ensure the audible high-level alarm system and automatic shutoff valve are functioning properly, if applicable.	
	3	Block the wheels of the tank truck.	
	4	Place drip pans under all pump hose fittings (if applicable) after the hose is hooked up to the AST and before unloading.	
	5	Ensure the fill nozzle is placed in the appropriate AST appurtenance. In this case, the fill nozzle is placed in the fill pipe connected to the round spill container.	
	6	Ensure the fill nozzle is placed in the appropriate tank appurtenance.	
During unloading:			
	7	Ensure that the facility representative and the tank truck operator remain with the vehicle at all times during unloading.	
	8	Monitor the gauges on the AST and the truck continuously to ensure the ullage is not exceeded. If the audible high-level alarm sounds, stop the unloading of fuel as soon as possible.	
The following six items must be completed after the fuel unloading has been completed:			
	9	Record the amount of fuel unloaded in the log (Appendix A, page A-1).	
	10	Before removing the fill hose from the AST, ensure that it is drained and that all drain valves are closed (if applicable).	
	11	Pour any fuel in the drip pans, tank truck containment pool, or spill container on the fill pipe into the AST (if it has the capacity) or dispose of appropriately (describe how it was disposed of, if applicable).	
	12	Inspect the tank truck before removing the blocks to ensure the lines have been disconnected from the AST.	
	13	Remove the blocks from tank truck wheels.	
	14	Place a copy of this fuel-unloading checklist in the SPCC BMP.	

APPENDIX B

TANK INSPECTION CHECKLIST

MONTHLY INSPECTION CHECKLIST			
Date of Inspection:	Tank Name or No.:		
Date of Last Inspection:	Inspected by:	Signature:	
A. TANKS	YES	NO	NOTES
1. Are tanks marked properly?			
2. Is area atop and around tank and within berm free of combustible materials, debris and stains?			
3. Is there any oil on the ground, concrete, or asphalt around the tank?			
4. Are there any visible cracks or indications of corrosion on the tank, at fittings, joints, or seals (such as paint peeling or rust spots)?			
5. Are there any raised spots, dents, or cracks on the tank?			
6. Does it appear that the foundation has shifted or settled?			
7. Is the fuel gauge working properly?			
8. Are all vents clear so they may properly operate?			
9. If rainwater is present within containment, does capacity remain for spill control (if applicable)?			
B. PIPING			
1. Is there any oil on the outside of or under any aboveground piping, hoses, fittings, or valves?			
2. Are aboveground piping, hoses, fittings, or valves in good working condition?			
C. SECURITY/SAFETY/SPILL COUNTERMEASURES			
1. Are lights working properly to detect a spill at night?			
2. Are all locks in the "lock" position?			
3. Are all warning signs properly posted and readable?			
4. Are vehicle guard posts in place and properly secured (if applicable)?			
5. Are spill kits easily accessible, protected from the weather, complete, and replenished if necessary?			
Corrective Actions Required:			

ANNUAL INSPECTION CHECKLIST (Page 1 of 1)				
Date of Inspection:		Tank Name or No.:		
Date of Last Inspection:		Inspected by:		
		Signature:		
A.	MONTHLY CHECKLIST	YES	NO	NOTES
1.	Have monthly inspection checklists been completed?			
B.	TANKS			
1.	Are all alarms and automatic shutoff devices working properly?			
2.	Is interstitial monitor functioning properly (if applicable)?			
C.	OTHER			
1.				
Corrective Actions Required:				

APPENDIX C
SPILL REPORTING FORM

**APPENDIX C
SPILL REPORTING**

1. GENERAL		
Name of Facility:	Address:	
Completed By:	Organization:	
Position:	Phone:	
2. SPILL INFORMATION		
Date:	Time:	
Location at Facility:	Quantity:	
Substance Spilled:	Other:	
3. OUTSIDE NOTIFICATIONS: (Insert telephone numbers)		
Agencies	Record the external regulatory agency representative name when making the calls.	Date & Time
Call 911 (or the local emergency agency), if there is an immediate emergency		
Regional Management (see Part III Section B subparagraph 1.b) (801) 524-5138 Ext 223		
Line Office Environmental Compliance Officer (see Part III Section B subparagraph 1b) (301) 713-1838 Ext. 165 or Ext 173		
NOAA, RECO (see Part III Section B subparagraph 1.c) (206) 526-6647		
EPA National Response Center or U.S. Coast Guard : (800) 424-8802		
State of California "Governor's Office of Emergency Services Warning Center" (800) 852-7550		
LECO — Ventura County HAZMAT (805) 654-2813		
4. INFORMATION ON SOURCE AND CAUSE		
5. DESCRIPTION OF ENVIRONMENTAL DAMAGE		
6. CLEANUP ACTION(S) TAKEN		
7. CORRECTIVE ACTION(S) TO PREVENT FUTURE SPILLS		

Note: All information must be filled in. If something is unknown, write "unknown".
Copies must be sent, preferably by e-mail, to the NWS/NOAA personnel listed above.

APPENDIX D
TRAINING OUTLINE & TRAINING RECORD

APPENDIX D-1

TRAINING OUTLINE: SPILL PREVENTION, CONTROL AND COUNTERMEASURES

Training will be provided for facility personnel at the following times:

1. System startup or whenever new equipment is installed
2. Within the first week of employment for new personnel
3. Annually

The training will include complete instruction in the elements of the facility's Spill Prevention, Control, and Countermeasure plan and will include the following:

1. Pollution control laws, rules, and regulations including a summary of Title 40 of the Code of Federal Regulations Part 112 "Oil Pollution Prevention" (see Attachment)
2. Fuel Storage System
 - A. Purpose and application of the following system elements:
 1. Tanks
 2. Piping
 3. Pumps
 4. Accessory equipment
 5. Electronic monitors
 - B. Operation, maintenance, and inspection of system elements
3. Spill Prevention
 - A. Potential spill sources
 - B. Spill flow direction and impact on navigable waters
 - C. Procedures to prevent spills, especially during fuel unloading
4. Spill Control
 - A. Secondary containment
 - B. Safety valves
 - C. Pump and equipment shutoff switches
 - D. Use of catch basin inlet covers or other diversionary devices
5. Spill Countermeasures
 - A. Location and use of emergency phone numbers
 - B. Location and use of fire extinguishers
 - C. Location and use of spill cleanup kit
 - D. Stopping the leak

APPENDIX E

MATERIALS SAFETY DATA SHEET ATTACHMENT

APPENDIX F

SPILL CLEANUP KIT INFORMATION ATTACHMENT

APPENDIX G
FUEL TANK DATA AND INFORMATION

APPENDIX H
PERMITS

APPENDIX I
PHOTOGRAPHS OF FACILITY TANKS AND PIPING

APPENDIX J (MAPS & DRAWINGS)

FIGURE 1:Site Location Map

FIGURE 2:Topographic Map & Site Layout

FIGURE 3: Site Piping Diagram